



Strojirenský zkušební ústav, s. p. (Engineering Test Institute, Public Enterprise),  
Hudcova 56b, 621 00 Brno, Czech Republic

# CERTIFICATE

Number: **B-30-01017-09**

Manufacturer: ŽDB GROUP a.s.  
Bezručova 300, 735 93 Bohumín, Czech Republic  
ID No.: 26877091  
Products: Sectional cast-iron hot-water boilers (operated with a fanned burner) burning extra light fuel oil  
Type designation: G 700  $X_1X_2X_3X_4$   
Trade mark: VIADRUS G 700  
for specification of variants and method of marking see page No. 2

These products have been certified within the meaning of Art. 10 of Act 22/1997 Coll., on the technical requirements for products and on the amendment to certain acts, as amended. The Engineering Test Institute hereby certifies that the characteristics of the samples of the products concerned have been found to be in conformity with the applicable requirements of

ČSN 06 1008:1997, ČSN EN 303-1:1999, ČSN EN 303-2:1999,  
ČSN EN 60335-1 ed.2:2003, ČSN EN 60335-2-102:2007  
and Government Regulation No. 148/2006 Coll.

Fulfilment of these requirements is considered to be fulfilment of the essential requirements of Government Regulation 163/2002 Coll., as amended.

The present Certificate has been issued on the basis of Final Report on Initial Product Type Testing No. 30-10435 of 2009-10-30, issued by the Engineering Test Institute. The period of validity of the Certificate is limited by the validity of the Final Report on Initial Product Type Testing, i.e. 2011-10-31.

The rules for using the Certificate are specified on Page 2.

Brno 2009-10-30



  
.....  
Jiří Rozsival  
Deputy Director

Specification of variants and method of marking:

Type of boiler		Rated output (kW)	Number of sections	Burner used		
				INTERCAL	BENTONE	WEISHAUPT
VIADRUS G 700 x <sub>1</sub> x <sub>2</sub> x <sub>3</sub> x <sub>4</sub>	G 700	330	10	SL 77/2	B 45 A2.2	WL 40-A
	G 700	400	11	SL 88/2	B 45 A2.2	WL 40-A
	G 700	470	12	SL 88/2	B 55-2	WL 40-A
	G 700	550	13	SL 88/2	B 55-2	L3Z-A
	G 700	650	14	CUENOD C 100 H 201	B 65-2	--
	G 700	750	15	CUENOD C 100 H 201	B 65-2	--

Legend to boilers marking:

x <sub>1</sub> – number of sections	10, 11, 12, 13, 14, 15
x <sub>2</sub> – method of supply	S - assembled position, R - dismantled position
x <sub>3</sub> – type of regulation	4 - electropanel – fitted with OS 04; 6 - electropanel – fitted with OS 06
x <sub>4</sub> – type of burner	0 - without burner, 1 - with burner

RULES FOR USING THE CERTIFICATE:

For the purpose of placing the products on the market, the Certificate may only be used provided that the normative documents specified on Page 1 have not changed. If the harmonized or determined standards applicable to the certified products have changed, or new standards have been issued, the usability of the Certificate must be reviewed.

The Certificate may only be used as a certificate for the products specified on Page 1 and 2. This also holds true for the use in advertising, promotional and commercial materials. Unauthorised or deceitful use of the Certificate may be sanctioned (Art. 19 of Act 22/1997 Coll., on the technical requirements for products and on the amendment to certain acts, as amended).

It is forbidden to change, amend or overwrite the data contained in the Certificate.

The Certificate may not be used for products changed without the consent of the Engineering Test Institute in such a way that conformity with the technical requirements specified on Page 1 is affected.

